

# Exhibit Z. Acadiana Regional Airport P4 Site FEMA 100 Year Flood Plain Letter & Map



### Acadiana Regional Airport P4 Site FEMA 100 Year Flood Plain Letter & Map



- 1. No attempt has been made by CSRS, Inc. to verify site boundary, title, actual legal ownership, deed restrictions, servitudes, easements, or other burdens on the property, other than that furnished by the client or his representative. 2. Transportation data from 2013 TIGER datasets via U.S. Census Bureau at ftp://ftp2.census.gov/geo/tiger/TIGER2013.
- 3. 2015 aerial imagery from USDA-APFO National Agricultural Inventory Project (NAIP) and may not reflect current ground conditions.
- 4. Effective FIRM Flood data provided by FEMA Flood Map Service Center (msc.fema.gov), FIRM panel no. 22045C0040E & 22045C0025E effective 12/2/2011.

Acadiana Regional Airport P4 Site . Iberia Parish, LA

#### One Acadiana





LEGEND

Site Boundary

**Ground Elevation Contours** 

Flood Zone X

#### **Existing Roadway**

Rural State Highway

Local Roads


**Site Details** Appx. Site Size: Area in 1% Flood Zone:

170.28 Ac. ±



Date:	10/8/2019
Project Number:	214002
Drawn By:	BNF
Checked By:	EEB
•	





## Acadiana Regional Airport P4 Site FEMA 100 Year Flood Plain Letter & Map



CSRS, INC. 6767 Perkins Road, Suite 200 Baton Rouge, Louisiana 70808

Phone: (225) 769-0546 Fax: (225) 767-0060

October 7, 2019

Mr. Zach Hager One Acadiana 804 East St. Mary Boulevard Lafayette, LA 70503

Re: Acadiana Regional Airport P4 Site

**FEMA Letter** 

CSRS Job No. 214002

Dear Mr. Hager:

According to the FEMA Digital Flood Insurance Rate Map (DFIRM) panel no. 22045C0040E and 22045C0025E of Iberia Parish, Louisiana, effective December 2, 2011, the Acadiana Regional Airport P4 Site is located in Flood Zone "X". In addition, according to the FEMA Effective DFIRM map provided on the LSU AgCenter website (http://maps.lsuagcenter.com), the site is located in Flood Zone "X". The LiDAR contours downloaded from LSU's ATLAS site indicate that the site ranges in elevation from 14 feet to 22 feet, however, the mean elevation of the developable property on the site is at elevation 19 feet.

No further action is needed to meet floodplain construction standards.

Thank you for the opportunity to assist you in this project. Should you have any questions or require additional information, feel free to contact me.

TAYLOR M. GRAVOIS REG. No. 33928

REGISTERED PROFESSIONAL ENGINEER

Sincerely,

CSRS, Inc.

Taylor M. Gravois, PE, PLS

WWW.CSRSINC.COM