


SYMBOL		DESCRIPTION
CEILING	FLUORESCENT FIXTURE	FLUORESCENT FIXTURE
WALL	EXIT SIGN	EXIT SIGN
	EMERGENCY BATTERY OPERATED FIXTURE	EMERGENCY BATTERY OPERATED FIXTURE
	MERCURY VAPOR WALL-PACK FIXTURE	MERCURY VAPOR WALL-PACK FIXTURE
	INCANDESCENT RLM LIGHT	INCANDESCENT RLM LIGHT
	JUNCTION BOX 4"	JUNCTION BOX 4"
RECESS	LIGHTING PANELBOARD	LIGHTING PANELBOARD
SURFACE	POWER OR DISTRIBUTION PANELBOARD	POWER OR DISTRIBUTION PANELBOARD
	LIGHTING CONTROL CABINET	LIGHTING CONTROL CABINET
	FLOOR OUTLET	FLOOR OUTLET
	MOTOR (NUMERAL INDICATES H.P.)	MOTOR (NUMERAL INDICATES H.P.)
	DISCONNECT SWITCH	DISCONNECT SWITCH
	SINGLE POLE SW. (SUBSCRIPT IS OUTLET CONTROLLED)	SINGLE POLE SW. (SUBSCRIPT IS OUTLET CONTROLLED)
	TRANSFORMER	TRANSFORMER
	JUNCTION BOX LARGER THAN 4"	JUNCTION BOX LARGER THAN 4"
	PUSH BUTTON STATION	PUSH BUTTON STATION
	CONDUIT EXPOSED	CONDUIT EXPOSED


NOTES:  
 1. THIS IS A TYPICAL SCHEDULE  
 2. ALL OUTLETS AND ELECTRICAL EQUIPMENT ARE SHOWN APPROXIMATELY LOCATED. FOR ALL MEASUREMENTS USE ARCHITECTURAL PLANS.



FLOOR PLAN - ARCHITECTURAL  
 EXISTING CONDITIONS SCALE: 1/2" = 50'-0"  
 GRAPHIC SCALE: 0' 12' 25' 50' 75' 100'


GENERAL NOTE: PERTAINING TO THIS SHEET ONLY  
 GN-1 EXISTING CONDITIONS SHOWN IN THIS SHEET ARE FOR INFORMATION, GENERAL AND FUTURE REFERENCE.

- REFERENCE NOTES: (PERTAINING POWER DISTR. SYSTEM-RISER DIAGRAM)
- ① EXISTING PRIMARY OIL FILLED DISCONNECT SWITCH (TYPICAL).
  - ② EXISTING STEP-DOWN 2400 VOLT/480/277 VOLT, 3 PHASE, 4 WIRE TRANSFORMER "T1" FOR EXISTING HIGH-BAY MERCURY FIXTURES (TYPICAL).
  - ③ EXISTING STEP-DOWN 2400 VOLT/208/120 VOLT, 1 PHASE, 3 WIRE TRANSFORMER "T2" FOR INCANDESCENT LIGHTS AND MISC. POWER (TYPICAL).
  - ④ EXISTING 2400 VOLT PRIMARY FEEDER (TYPICAL).
  - ⑤ EXISTING 480/277 VOLT SECONDARY FEEDER (TYPICAL).
  - ⑥ EXISTING 208/120 VOLT SECONDARY FEEDER (TYPICAL).



KEY PLAN  
 SCALE: NONE

**BLITCH / MOSES** a joint venture  
 Blitch Architects Inc.  
 757 St. Charles Avenue  
 New Orleans, Louisiana 70130  
 Warren G. Moses & Co., Inc.  
 Consulting Engineers  
 929 Howard Avenue  
 New Orleans, Louisiana 70113



POWER DISTRIBUTION SYSTEM - RISER DIAGRAM  
 EXISTING CONDITION N.T.S.

DWG. NO.	SEQ. NO.	DESCRIPTION
E-1	1	FLOOR PLAN - ARCHITECTURAL EXISTING CONDITIONS, ONE LINE RISER DIAGRAM - POWER DISTRIBUTION SYS. & KEY PLAN
E-2	2	UNIT "A" LIGHTING - EXISTING CONDITIONS
E-3	3	UNIT "B" LIGHTING - EXISTING CONDITIONS
E-4	4	UNIT "C" LIGHTING - EXISTING CONDITIONS
E-5	5	UNIT "D" LIGHTING - EXISTING CONDITIONS
E-6	6	UNIT "E" LIGHTING - EXISTING CONDITIONS

NOTE  
 ALL MEASUREMENTS must be verified at building by the contractor before work indicated hereon is started.

DESIGN AND CONSTRUCTION DIVISION  
 REGION 7 - FORT WORTH, TEXAS  
 "AR" "EE" "ME" "ST"

GENERAL SERVICES ADMINISTRATION  
 OFFICE OF PUBLIC BUILDINGS AND REAL PROPERTY

BUILDING	WAREHOUSE NO. 2		
LOCATION	HARAHAN, LOUISIANA		
STREET	500 EDWARDS AVENUE		
PROJ. NO.	RLA93085	BLDG. NO.	LA0692HL
DRAWN BY	CATZABON	CHECKED BY	SOUSA
PROJECT TITLE	DESIGN SERVICES FOR LIGHTING RETROFIT		
DRAWING TITLE	FLOOR PLAN - ARCHITECTURAL EXISTING CONDITIONS, ONE LINE RISER DIAGRAM - POWER DISTRIBUTION SYS. & KEY PLAN		
DRAWING NO.	E-1	1 OF 6	SEQUENCE

