



Exhibit J. NRG Industrial Park Wastewater Infrastructure Upgrade Letter

CSRS, INC.

6767 Perkins Road, Suite 200
Baton Rouge, Louisiana 70808

Phone. (225) 769-0546
Fax. (225) 767-0060

July 25, 2013

Mr. Jim Cavanaugh
Baton Rouge Area Chamber
564 Laurel Street
Baton Rouge, LA 70801

Re. NRG Industrial Site
CSRS Job No. 212161.004

Dear Mr. Cavanaugh:

According to correspondence with local utility officials and operators of Big Cajun II, the NRG site located on LA 981 near the intersection of LA 981 and LA 10 has no existing wastewater infrastructure to service the site.

In order to provide a wastewater treatment facility to treat 250,000 gallons per day (gpd), the site would require the construction of a new wastewater treatment facility. Before the individual industry discharges to the treatment facility, pretreatment requirements necessitate strengths less than or equal to 200 mg/L 5-day Biological Oxygen Demand (BOD) and 200 mg/L Total Suspended Solids. After treatment at the wastewater treatment facility, treated wastewater then may be discharged to the Mississippi River via an existing 30" wastewater line on Big Cajun II property. Expected discharge limits of BOD₅, TSS, NH₃, and Phosphorous are 30/30/2/5 mg/L, respectively. Providing service for a total capacity of 250,000 gpd would yield a peak demand of approximately 806,400 gpd and an excess capacity of approximately 500,000 gpd. The construction cost of this new wastewater treatment facility is estimated to be \$1.2 million; however, costs can vary depending on the size and use of the facility. Please note that this estimate does not include engineering, rights of way acquisition, environmental impacts or operation and maintenance costs. This plan can be executed within a reasonable timetable of 180 days or less based on preliminary engineering judgment.

Thank you for the opportunity to assist you in this project. Should you have any questions or require additional information, feel free to contact me.

Sincerely,

CSRS, Inc.

Taylor M. Gravois, PE, PLS