



www.denmon.com

TERRY D.
DENMON, P.E., P.L.S.

THOMAS M.
BONNETTE, P.E.

CHRIS W.
PATRICK, P.E.

RANDY A.
DENMON, P.E., P.L.S.

ROBERT B.
HARRELL, P.E.

WALTER
CARPENTER, JR., P.E.

CHARLES N.
HATCH, P.L.S.

Exhibit V, River Road Waterworks Letter DENMON ENGINEERING

Engineers and Surveyors

MONROE • BOSSIER CITY

CORPORATE OFFICES LOCATED ON US 165 NORTH AT VENABLE LANE

P.O. BOX 8460 MONROE, LOUISIANA 71211-8460

TELEPHONE: 318-388-1422 FAX: 318-361-5036

EMAIL: mail@denmon.com • WEBSITE: www.denmon.com

October 22, 2013

Re: LED/NELA Site Certification for the Bee Bayou Site – River Road
Waterworks.

Denmon Engineering was the design firm for the River Road Water System in the vicinity of the Bee Bayou and Holly Ridge Sites. We have reviewed the system design, and met with the current operator. Based on this, we confirm that the design capacity of the existing system is approximately 900,000 gpd, with a current usage of 200,000 gpd. In the Holly Ridge, Bee Bayou area, approximately 400,000 gpd of additional capacity exist.

If you have any questions or comments, please feel free to call me.

Sincerely,

DENMON ENGINEERING COMPANY, INC.



RANDY A. DENMON, P.E., P.L.S.

RAD/rad