

# Exhibit 12

## Fire Protection Plan



City of Natchitoches  
Highway 478 Development Tract

The site will be served with adequate water supply to combat fires at the site. Once the water extension is completed, water pressure at the site will be 42 psi through 12" pipe

A connection point will be installed onsite to facilitate fire suppression.

