



www.denmon.com

TERRY D.
DENMON, P.E., P.L.S.

THOMAS M.
BONNETTE, P.E.

CHRIS W.
PATRICK, P.E.

RANDY A.
DENMON, P.E., P.L.S.

ROBERT B.
HARRELL, P.E.

WALTER
CARPENTER, JR., P.E.

CHARLES N.
HATCH, P.L.S.
(1945-2014)

DENMON ENGINEERING

Engineers and Surveyors

MONROE • BOSSIER CITY

CORPORATE OFFICES LOCATED ON US 165 NORTH AT VENABLE LANE

P.O. Box 8460 MONROE, LOUISIANA 71211-8460

TELEPHONE: 318-388-1422 FAX: 318-361-5036

EMAIL: mail@denmon.com • WEBSITE: www.denmon.com

CITY OF MONROE

WATER AND SEWER SYSTEM CAPACITY

Water Capacity:

Total Current Maximum Water System Treatment Capacity:	19.5 MGD
Excess capacity for the 12" water line along Highway 594:	1.3 MGD
Total approx. capacity of the 12" water line along Highway 594:	2.3 MGD

Sewer Capacity:

Total Current Maximum Sewer Treatment Plant Capacity:	21 MGD
Excess capacity of Sewer Treatment Plant:	10 MGD
Total capacity of the lift station located on Highway 594:	1.3 MGD

Chris W. Patrick