



Exhibit M. Waterloo Site Potable Water Infrastructure Upgrade Letter

CSRS, INC.

6767 Perkins Road, Suite 200
Baton Rouge, Louisiana 70808

Phone. (225) 769-0546
Fax. (225) 767-0060

October 29, 2013

Mr. Jim Cavanaugh
Baton Rouge Area Chamber
564 Laurel Street
Baton Rouge, LA 70801

Re. Barber Brothers Site
CSRS Job No. 212161.005

Dear Mr. Cavanaugh:

According to correspondence with Roland Jackson of Ascension Water Company the Barber Brothers site located on LA 75 near Geismar, LA does not have existing potable/process water on the site. The nearest water main, operated by Ascension Water, is located on the west side of LA Hwy 73 approximately 4,000' from the site boundary. In order to provide adequate potable water supply, the most cost effective option would be to construct a connecting water line to tie into the existing 12" water main.

The estimated construction cost of extending an 12" main 4,000 L.F. that can provide 250,000 gallons per day is \$516,207. Please note that this estimate does not include engineering, servitude acquisition, environmental impacts or operation and maintenance costs. In addition these costs can vary based on the availability of material and labor.

Thank you for the opportunity to assist you in this project. Should you have any questions or require additional information, feel free to contact me.

Sincerely,

CSRS, Inc.

Taylor M. Gravois, PE, PLS

